

23.19 DISLOCIRANE I/O ENOTE KRMILNIKA SISTEMA VODENJA

Poz.	Opis	Ponudbeni opis naprave
1.	Proizvajalec	
2.	Tip in oznaka celotnega sklopa (dislocirana enota, kartice DI/DO, napajalnik, komunikacijski moduli,...)	
3.	Napajalna napetost 24 V DC	
4.	Število digitalnih vhodov min. 96	
5.	Število digitalnih izhodov min.48	
6.	Komunikacijski priključki Profibus	
7.	Dobavitelj je seznanjen s celotnim opisom naprave v tehničnem opisu in zahtevami za opremo, ki je predmet ponudbe in se v celoti sklada z zahtevami v celotni razpisni dokumentaciji	Podpis odgovorne osebe:

Opomba: zaradi kompatibilnosti z obstoječo opremo in sistemom vodenja SENG je zaželeno, da je vsa nova oprema kot je že dobavljena na objektu proizvajalca Siemens (kompatibilna s programom PCS 7), ki je razvidna v spodnji tabeli.

Zunanji napajalnik	SITOP 10 A, 230 V AC/ 24 V DC
6DL1131-6BH00-0PH1	ET 200SP HA, DI 16X24VDC
6DL1134-6AF00-0PH1	ET 200SP HA, AI 8xU/I/TC/4xRTD HA
6DL1155-6AU00-0PM0	ET 200SP HA, IM155-6 PN
6DL1193-6AG00-0AA0	ET 200SP HA, BUSADAPTER BA 2XLC
6DL1193-6BH00-0SM0	CARRIER MODULE IM SINGLE
6DL1193-6GA00-0NN0	CARRIER MODULE TWOFOLD
6DL1193-6MC00-0AA0	MOUNTING RAIL 482MM (19")
6DL1132-6BH00-0PH1	SIMATIC ET 200SP HA, DQ 16X24VDC/0,5A HA
6GK5206-2BB00-2AC2	SCALANCE XC206-2 manageable Layer 2 IE switch; 6x 100 Mbit/s RJ45 ports; 2x 100 Mbit/s ST/BFOC ports (2 kosa)
6DL1193-6TP00-0DH1	TERMINAL BLOCK, TYPE H1, LIGHT-GREY
6DL1193-6TP00-0BH1	Terminal block, Type H1, 32 push-in terminals
7KM3220-1BA01-1EA0 + 7KM9300-0AE02-0AA0	SETRON PAC3220, napajanje 24 VDC z PROFINET modulom