

	TECHNICAL SPECIFICATION FOR SUPERVISION SERVICE FOR CIRCULATION PUMPS ON FDG 6	Rev. 0 Date. 01.10.22 Page 1 of 2
---	---	--

TECHNICAL SPECIFICATION FOR SUPERVISION SERVICE FOR CIRCULATION PUMPS ON FDG 6

Content

1. SCOPE OF SERVICES..... 2

Actual specification includes **2** pages

	TECHNICAL SPECIFICATION FOR SUPERVISION SERVICE FOR CIRCULATION PUMPS ON FDG 6	Rev. 0 Date. 01.10.22 Page 2 of 2
---	---	--

1. SCOPE OF SERVICES

Supervision service (LOT 10)

- Inspection of the rotor and casing of all recirculation pumps of scrubber.

List of the pumps type MCC 800-1070 II Evo DÜTEC Standard:

- 06HTF11AP001
- 06HTF12AP001
- 06HTF13AP001
- 06HTF14AP001
- 06HTF15AP001
- 06HTF16AP001

During the inspection of the pumps the supplier must provide the supervisor technical assistance and guide the local personnel. All special tools needed to perform the intended erection work will be provided by TEŠ (hydraulic units for dismantling the rotor, rack for the rotor, special tools, etc.).

Main tasks:

- Removing of the entire pump from the platform
- Inspection of the volute casing
- Inspection of the impeller
- Removing and installation of the impeller
- Inspection of the discharge cover
- Inspection of the mechanical seal