


MAXIMUM DISTANCES AND WIRE CROSS-SECTION AREAS

Maximum distance (m) between		Wire cross-section area (mm ²)
- external device and reset button	100 m	0,5 mm ²
- external device and SOS button	100 m	0,5 mm ²
- external device and internal device	100 m	0,5 mm ²

 Wires with cross-section area of 0.5 mm² / AWG20 or larger must comply with IEC 60332-1-2; wires with cross-section area smaller than 0.5 mm² / AWG20 must comply with IEC 60332-2-2.