



In pursuance of Article 90 of the Public Procurement Act (ZJN-3 Official Gazette of the Republic of Slovenia No. 91/15, 14/18, 121/21, 10/22 and 28/23) Nuklearna elektrarna Krško, d.o.o., Vrbina 12, 8270 Krško (hereinafter: Purchaser), represented by Gorazd Pfeifer, President of the Management Board, and Saša Medaković, Member of the Management Board, issues a

DECISION ON REJECTION OF ALL BIDS

For the "Supply of Power Supplies for ACM7300 Instrumentation System (SR)"

1. Explanation of public procurement procedure

With reference to Article 45 of ZJN-3, the Purchaser provided the Bidding Documentation No.: 146/25-8250881 for **"Supply of Power Supplies for ACM7300 Instrumentation System (SR)"** according to Negotiating procedure with prior notification. The public procurement procedure was published on Slovenia Public Procurement Portal under JN005487/2025-EUe17/01 on July 14, 2025.

2. Information on received Bids

By the Bidding deadline, August 21, 2025 the Purchaser received two (2) Bids with the following basic elements:

No.	Name and address of the Bidder	Currency	Total value without VAT
1	Westinghouse Electric Company, LLC., 1000 Westinghouse Drive, New Stanton, PA 15672, USA	USD	511.833,00
2	Ametek Solidstate Controls, 875 Dearborn Dr, Columbus, OH 43085, USA	USD	713.925,00

3. Bids Review and Negotiations

Upon review of the Bids, the Purchaser found that certain clarifications or amendments are required from both Bidders.

Both bidders were invited on August 28, 2025, to clarify/amend their Bids.

The Bidder Ametek Solidstate Controls has specified the delivery deadline more precisely.
The Bidder Westinghouse has provided additional clarifications regarding the alternative product.

On October 30, 2025 the Purchaser invited both Bidders to submit their Final Bids.

By the Final extended Bid due date, November 12, 2025, Purchaser received two (2) Final Bids with the following basic elements:

No.	Name and address of the Bidder	Currency	Total value without VAT
1	Westinghouse Electric Company, LLC., 1000 Westinghouse Drive, New Stanton, PA 15672, USA	USD	397.500,00
2	Ametek Solidstate Controls, 875 Dearborn Dr, Columbus, OH 43085, USA	USD	488.800,00

4. Final Bids Review and Evaluation

Following the review of the Final Bids, the Purchaser finds that both received Final Bids are inadmissible.

Westinghouse

The Bid submitted by Westinghouse is rejected as inadmissible because it does not meet the technical requirements of the Purchaser. In the Bidding Documentation, the Purchaser required Power Supplies with a capacity of 60 A. In its final Bid, the Bidder offered Power Supplies with a capacity of 50 A.

On November 21, 2025, the Purchaser requested clarification of the discrepancy. In its clarification dated November 24, 2025, the Bidder stated that the offered Power Supplies achieve 50 A. In subsequent supplements dated December 9, 2025, and December 17, 2025, the Bidder claimed that the offered Power Supplies achieve the required 60 A, which it sought to prove through additional testing carried out after the deadline for submission of final Bids. The Purchaser could not take such clarification into account, as under Article 89 of the Public Procurement Act (ZJN-3), supplementing a Bid in the part related to technical specifications is not permitted. Clarifications may only relate to elements whose existence can be objectively verified before the deadline for submission of Bids. Since the official documentation submitted with the Bid shows non-compliance with the requirements, and subsequently created evidence (testing) would constitute an actual change in the technical characteristics of the offered item after the deadline, the Purchaser cannot allow such changes due to the principle of equal treatment of Bidders and transparency.

Ametek

The Bid submitted by Ametek is rejected as inadmissible because the Bidder made unauthorized changes to the content of the final contract. In its final Bid, the Bidder proposed amendments to contractual provisions that deviate from the requirements set out in the Bidding Documentation, thereby rendering the Bid non-compliant with all the Purchaser's requirements.

5. Proposal for Issuing a Decision on Rejection of Bids

Based on all of the above, the Purchaser proposes that a decision be adopted to reject both Bids for the Supply of Power Supplies for the ACM7300 System. Since no admissible Bid remains in the

procedure, the public procurement process shall be concluded without selection.

Legal instruction

The rejected Bidders are allowed to submit a request for review/revision within eight working days from the receipt of the decision on award or elimination of public procurement in compliance with Legal Protection in Public Procurement Procedures Act (ZPVPJN, OG RS No. 43/11, 63/13, 60/17 and 72/19). Request for revision shall be submitted by portal eRevizija. The applicant must submit with the request for review the bank certificate for the payment of tax in the amount of EUR 1.000,00 to the account of the Ministry of Finance No.: 01100-1000358802, reference 11 16110-7111290-00548725.

4.
Saša Medaković
Member of the Management Board

Gorazd Pfeifer
President of the Management Board

Krško, January 13, 2026

