

Technical specification for Items

1. SCOPE

Line	NEK Item Number	Part Number	UOM	Quantity	Need by Date	Safety Classification
1	432739	P45-0352	FT	16000	30-Oct-26	SR
	CABLE.POWER,SC:SR,NO. CONDUCTORS:SINGLE,CONDUCTOR SIZE:350 MCM,SOLID/STRANDED:37 STRANDS,COND. MATERIAL:BARE COPPER,VOLTS:8kV,SHIELDING:TINNED COPPER TAPE,INSUL. MATERIAL:PROPRIETARY KERITE,JACKET MATERIAL:CSPE,CLASS:B,COLOR:BLACK,STANDARD:SPEC.; RSS-7- 010,O.D.DIA:1,26inch (32mm)					
	MFG: ROCKBESTOS CO, ROCKBESTOS CO, , United States Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02 The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT X17 - SUPPLEMENT DOCUMENTS					
2	154810	P62-0114	FT	3000	30-Oct-26	SR
	CABLE,POWER,NO. CONDUCTORS:3/C,CONDUCTOR SIZE:10AWG,SOLID/STRANDED:7 STRAND,COND. MATERIAL:COPPER TIN-COATED,VOLTS:600V,TEMP. RATING:90DEGC,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,TYPE:TC,(MNF.:ROCKBESTOS),SC:SR					
	MFG: ROCKBESTOS CO, ROCKBESTOS CO, , United States Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02 The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT X17 - SUPPLEMENT DOCUMENTS					
3	154810	P62-0114	FT	8000	30-Oct-27	SR

	CABLE,POWER,NO. CONDUCTORS:3/C,CONDUCTOR SIZE:10AWG,SOLID/STRANDED:7 STRAND,COND. MATERIAL:COPPER TIN-COATED,VOLTS:600V,TEMP. RATING:90DEGC,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,TYPE:TC,(MNF.:ROCKBESTOS),SC:SR					
	MFG: ROCKBESTOS CO, ROCKBESTOS CO, , United States Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02 The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT X17 - SUPPLEMENT DOCUMENTS					
4	154810	P62-0114	FT	3000	31-Mar-28	SR
	CABLE,POWER,NO. CONDUCTORS:3/C,CONDUCTOR SIZE:10AWG,SOLID/STRANDED:7 STRAND,COND. MATERIAL:COPPER TIN-COATED,VOLTS:600V,TEMP. RATING:90DEGC,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,TYPE:TC,(MNF.:ROCKBESTOS),SC:SR MFG: ROCKBESTOS CO, ROCKBESTOS CO, , United States Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02 The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT X17 - SUPPLEMENT DOCUMENTS					
5	235373	P62-0116	FT	1000	31-Mar-28	SR
	CABLE,POWER,SC:SR,NO. CONDUCTORS:4/C,CONDUCTOR SIZE:10AWG,SOLID/STRANDED:7,COND. MATERIAL:TIN COATED COPPER,VOLTS:600V,TEMP. RATING:90degC,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:NEC TC MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02 The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT X17 - SUPPLEMENT DOCUMENTS					

6	154811	P62-0124	FT	3000	30-Oct-26	SR
	CABLE,POWER,NO. CONDUCTORS:3/C,CONDUCTOR SIZE:12AWG,SOLID/STRANDED:7 STRAND,COND. MATERIAL:COPPER TIN-COATED,VOLTS:600V,TEMP. RATING:90DEGC,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,TYPE:TC,(MNF.:ROCKBESTOS),SC:SR					
	MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States					
	<p>Item shall be supplied in accordance with the following TQRs: F03, F66, F80, F81, F82, F84, F85, F86, F88</p> <p>The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS</p>					
7	154811	P62-0124	FT	8000	30-Oct-27	SR
	CABLE,POWER,NO. CONDUCTORS:3/C,CONDUCTOR SIZE:12AWG,SOLID/STRANDED:7 STRAND,COND. MATERIAL:COPPER TIN-COATED,VOLTS:600V,TEMP. RATING:90DEGC,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,TYPE:TC,(MNF.:ROCKBESTOS),SC:SR					
	MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States					
	<p>Item shall be supplied in accordance with the following TQRs: F03, F66, F80, F81, F82, F84, F85, F86, F88</p> <p>The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS</p>					
8	154811	P62-0124	FT	3000	31-Mar-28	SR
	CABLE,POWER,NO. CONDUCTORS:3/C,CONDUCTOR SIZE:12AWG,SOLID/STRANDED:7 STRAND,COND. MATERIAL:COPPER TIN-COATED,VOLTS:600V,TEMP. RATING:90DEGC,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,TYPE:TC,(MNF.:ROCKBESTOS),SC:SR					
	MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States					
	<p>Item shall be supplied in accordance with the following TQRs: F03, F66, F80, F81, F82, F84, F85, F86, F88</p> <p>The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS</p>					
9	420132	P62-0126	FT	3000	30-Oct-26	SR
	CABLE.POWER,SC:SR,NO. CONDUCTORS:4/C,CONDUCTOR SIZE:12AWG,SOLID/STRANDED:7 STRAND,COND. MATERIAL:COPPER TIN-COATED,VOLTS:600V,TEMP. RATING:90DEGC,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,TYPE:TC					
	MFG: ROCKBESTOS CO, ROCKBESTOS CO, , United States					
	<p>Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02</p> <p>The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS</p>					

	G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT X17 - SUPPLEMENT DOCUMENTS					
10	120965	P62-5036	FT	3000	30-Oct-26	SR
	CABLE,POWER,NO. CONDUCTORS:4/C,CONDUCTOR SIZE:8AWG,SOLID/STRANDED:7 STRAND,COND. MATERIAL:COPPER,VOLTS:600V,TEMP. RATING:90C,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,SC:SR MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States Item shall be supplied in accordance with the following TQRs: F03, F66, F80, F81, F82, F84, F85, F86, F88 The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS					
11	120965	P62-5036	FT	3000	30-Oct-27	SR
	CABLE,POWER,NO. CONDUCTORS:4/C,CONDUCTOR SIZE:8AWG,SOLID/STRANDED:7 STRAND,COND. MATERIAL:COPPER,VOLTS:600V,TEMP. RATING:90C,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,SC:SR MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States Item shall be supplied in accordance with the following TQRs: F03, F66, F80, F81, F82, F84, F85, F86, F88 The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS					
12	420112	P62-0204	FT	2000	30-Oct-26	SR
	CABLE,POWER,NO. CONDUCTORS:3/C,CONDUCTOR SIZE:2/0 AWG,SOLID/STRANDED:19 STRANDS,COND. MATERIAL:COPPER,VOLTS:600V,TEMP. RATING:90DEGC,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:TC,(WITH THREE GROUND WIRE,SPEC. RCC-3-021,MNF.:ROCKBESTOS),SC:SR MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02 The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT X17 - SUPPLEMENT DOCUMENTS					
13	420111	P62-5041	FT	2000	30-Oct-26	SR

14	CABLE,POWER,NO. CONDUCTORS:4/C,CONDUCTOR SIZE:2/0 AWG,SOLID/STRANDED:19 STRANDS,COND. MATERIAL:COPPER,VOLTS:600V,TEMP. RATING:90DEGC,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:TC,(WITH THREE GROUND WIRE,SPEC. RCC-3-021,MNF.:ROCKBESTOS),SC:SR					
	MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States					
	<p>Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02</p> <p>The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT X17 - SUPPLEMENT DOCUMENTS</p>					
14	120967	P62-5043	FT	2000	30-Oct-26	SR
	CABLE,POWER,NO. CONDUCTORS:4/C,CONDUCTOR SIZE:4/0 AWG,SOLID/STRANDED:19 STRAND,COND. MATERIAL:COPPER,VOLTS:600V,TEMP. RATING:90C,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,SC:SR					
	<p>Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02</p> <p>The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT X17 - SUPPLEMENT DOCUMENTS</p>					
15	149752	P62-5040	FT	1000	31-Mar-28	SR
	CABLE,POWER,NO. CONDUCTORS:4/C,CONDUCTOR SIZE:1/0 AWG,SOLID/STRANDED:19 STRAND,COND. MATERIAL:COPPER TIN-COATED,VOLTS:600V,TEMP. RATING:90DEGC,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:TC,(SPEC. RSS-3-021,MNF.:ROCKBESTOS),SC:SR					
	<p>MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States</p> <p>Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02</p> <p>The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT X17 - SUPPLEMENT DOCUMENTS</p>					

16	420110	P62-3119	FT	1000	31-Mar-28	SR
CABLE,POWER,NO. CONDUCTORS:3/C,CONDUCTOR SIZE:1 AWG,SOLID/STRANDED:19 STRANDS,COND. MATERIAL:COPPER,VOLTS:600V,TEMP. RATING:90DEGC,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:TC,(WITH THREE GROUND WIRE,SPEC. RCC-3-021,MNF.:ROCKBESTOS),SC:SR						
MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States						
Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02						
The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT X17 - SUPPLEMENT DOCUMENTS						
17	420109	P62-5039	FT	1000	31-Mar-28	SR
CABLE,POWER,NO. CONDUCTORS:4/C,CONDUCTOR SIZE:1 AWG,SOLID/STRANDED:19 STRANDS,COND. MATERIAL:COPPER,VOLTS:600V,TEMP. RATING:90DEGC,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:TC,(WITH THREE GROUND WIRE,SPEC. RCC-3-021,MNF.:ROCKBESTOS),SC:SR						
MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States						
Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02						
The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT X17 - SUPPLEMENT DOCUMENTS						
18	120963	P62-0024	FT	1000	31-Mar-28	SR
CABLE,POWER,NO. CONDUCTORS:3/C,CONDUCTOR SIZE:2AWG,SOLID/STRANDED:7 STRAND,COND. MATERIAL:COPPER,VOLTS:600V,TEMP. RATING:90C,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,SC:SR						
MFG: ROCKBESTOS CO, ROCKBESTOS CO, , United States						
Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02						
The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS						

	G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT X17 - SUPPLEMENT DOCUMENTS					
19	123084	C53-0020	FT	10000	30-Oct-26	SR
CABLE,CONTROL,NO. CONDUCTORS:2/C,CONDUCTOR SIZE:14AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER TIN-COATED,VOLTS:600V,TEMP. RATING:90C,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:TC,(SPEC. RSS-3-021,MNF.:ROCKBESTOS),SC:SR						
MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02 The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT X17 - SUPPLEMENT DOCUMENTS						
20	123084	C53-0020	FT	20000	30-Oct-27	SR
CABLE,CONTROL,NO. CONDUCTORS:2/C,CONDUCTOR SIZE:14AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER TIN-COATED,VOLTS:600V,TEMP. RATING:90C,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:TC,(SPEC. RSS-3-021,MNF.:ROCKBESTOS),SC:SR						
MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02 The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT X17 - SUPPLEMENT DOCUMENTS						
21	123084	C53-0020	FT	5000	31-Mar-28	SR
CABLE,CONTROL,NO. CONDUCTORS:2/C,CONDUCTOR SIZE:14AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER TIN-COATED,VOLTS:600V,TEMP. RATING:90C,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:TC,(SPEC. RSS-3-021,MNF.:ROCKBESTOS),SC:SR						
MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02						

	<p>The following documents and/or records shall be submitted with the above item:</p> <p>G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT X17 - SUPPLEMENT DOCUMENTS</p>					
22	118727	C53-0030	FT	5000	30-Oct-26	SR
<p>CABLE.CONTROL,SC:SR,NO. CONDUCTORS:3/C,CONDUCTOR SIZE:14AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER,VOLTS:600V,TEMP. RATING:90C,INSUL. MATERIAL:XLPE/CSPE,JACKET MATERIAL:SCPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:K1</p> <p>MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States</p> <p>Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02</p> <p>The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT X17 - SUPPLEMENT DOCUMENTS</p>						
23	118727	C53-0030	FT	10000	30-Oct-27	SR
<p>CABLE.CONTROL,SC:SR,NO. CONDUCTORS:3/C,CONDUCTOR SIZE:14AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER,VOLTS:600V,TEMP. RATING:90C,INSUL. MATERIAL:XLPE/CSPE,JACKET MATERIAL:SCPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:K1</p> <p>MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States</p> <p>Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02</p> <p>The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT X17 - SUPPLEMENT DOCUMENTS</p>						
24	118727	C53-0030	FT	5000	31-Mar-28	SR
<p>CABLE.CONTROL,SC:SR,NO. CONDUCTORS:3/C,CONDUCTOR SIZE:14AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER,VOLTS:600V,TEMP. RATING:90C,INSUL. MATERIAL:XLPE/CSPE,JACKET MATERIAL:SCPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:K1</p> <p>MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States</p>						

	<p>Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02</p> <p>The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT X17 - SUPPLEMENT DOCUMENTS</p>					
25	123704	C53-0050	FT	5000	30-Oct-26	SR
	<p>CABLE,CONTROL,NO. CONDUCTORS:5/C,CONDUCTOR SIZE:14AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER,VOLTS:600V,TEMP. RATING:90C,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:TC,(SPEC. RSS-3-021,MNF.:ROCKBESTOS),SC:SR</p> <p>MFG: ROCKBESTOS CO, ROCKBESTOS CO, , United States</p> <p>Item shall be supplied in accordance with the following TQRs: F03, F80, F81, F82, F84, F85, F86, F88</p> <p>The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS</p>					
26	123704	C53-0050	FT	5000	30-Oct-27	SR
	<p>CABLE,CONTROL,NO. CONDUCTORS:5/C,CONDUCTOR SIZE:14AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER,VOLTS:600V,TEMP. RATING:90C,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:TC,(SPEC. RSS-3-021,MNF.:ROCKBESTOS),SC:SR</p> <p>MFG: ROCKBESTOS CO, ROCKBESTOS CO, , United States</p> <p>Item shall be supplied in accordance with the following TQRs: F03, F80, F81, F82, F84, F85, F86, F88</p> <p>The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS</p>					
27	123700	C52-0020	FT	2000	30-Oct-27	SR
	<p>CABLE,CONTROL,NO. CONDUCTORS:2/C,CONDUCTOR SIZE:12AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER,VOLTS:600V,TEMP. RATING:90C,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:FIREWALL III,(SPEC. RSS-3-021,MNF.:ROCKBESTOS),SC:SR</p> <p>MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States</p> <p>Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02</p> <p>The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE</p>					

	G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT X17 - SUPPLEMENT DOCUMENTS					
28	144490	C52-0030	FT	3000	30-Oct-26	SR
	CABLE,CONTROL,NO. CONDUCTORS:3/C,CONDUCTOR SIZE:12AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER,VOLTS:600V,TEMP. RATING:90C,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,TYPE:TC,(SPEC. RSS-3-021, MNF.:ROCKBESTOS COMP.),SC:SR MFG: ROCKBESTOS CO, ROCKBESTOS CO, , United States Item shall be supplied in accordance with the following TQRs: F03, F80, F81, F82, F84, F85, F86, F88 The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS					
29	144490	C52-0030	FT	2000	30-Oct-27	SR
	CABLE,CONTROL,NO. CONDUCTORS:3/C,CONDUCTOR SIZE:12AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER,VOLTS:600V,TEMP. RATING:90C,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,TYPE:TC,(SPEC. RSS-3-021, MNF.:ROCKBESTOS COMP.),SC:SR MFG: ROCKBESTOS CO, ROCKBESTOS CO, , United States Item shall be supplied in accordance with the following TQRs: F03, F80, F81, F82, F84, F85, F86, F88 The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS					
30	407426	C52-0040	FT	3000	30-Oct-26	SR
	CABLE,CONTROL,SC:SR,NO. CONDUCTORS:4/C,CONDUCTOR SIZE:12AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER TIN-COATED,VOLTS:600V,TEMP. RATING:90DEGC,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,TYPE:FIREWALL III MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02 The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT X17 - SUPPLEMENT DOCUMENTS					

31	123701	C52-0050	FT	3000	30-Oct-27	SR
32	120304	C51-0020	FT	3000	30-Oct-27	SR
33	124712	C51-0030	FT	1000	31-Mar-28	SR

	GP4 - PRODUCT DATA SHEET X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT X17 - SUPPLEMENT DOCUMENTS					
34	123702	C51-0050	FT	2000	30-Oct-26	SR
CABLE,CONTROL,NO. CONDUCTORS:5/C,CONDUCTOR SIZE:10AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER,VOLTS:600V,TEMP. RATING:90C,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:TC,(SPEC. RSS-3-021,MNF.:ROCKBESTOS),SC:SR MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02 The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT X17 - SUPPLEMENT DOCUMENTS						
35	123703	I46-0020	FT	3000	30-Oct-26	SR
CABLE,INSTRUMENTATION,NO. CONDUCTORS:2/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:NEC TYPE TC,(SPEC. RSS-,SC:SR MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States Item shall be supplied in accordance with the following TQRs: F03, F80, F81, F82, F84, F85, F86, F88 The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS						
36	123703	I46-0020	FT	4000	30-Oct-27	SR
CABLE,INSTRUMENTATION,NO. CONDUCTORS:2/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:NEC TYPE TC,(SPEC. RSS-,SC:SR MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States Item shall be supplied in accordance with the following TQRs: F03, F80, F81, F82, F84, F85, F86, F88 The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS						
37	120217	I46-0021	FT	10000	30-Oct-27	SR

	CABLE,INSTRUMENTATION,NO. CONDUCTORS:2/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER TINNED,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:TC,(SPEC. RSS-3-,SC:SR MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States Item shall be supplied in accordance with the following TQRs: F03, F80, F81, F82, F84, F85, F86, F88 The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS					
38	120217	I46-0021	FT	5000	31-Mar-28	SR
	CABLE,INSTRUMENTATION,NO. CONDUCTORS:2/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER TINNED,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:TC,(SPEC. RSS-3-,SC:SR MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States Item shall be supplied in accordance with the following TQRs: F03, F80, F81, F82, F84, F85, F86, F88 The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS					
39	118770	I46-0031	FT	3000	30-Oct-26	SR
	CABLE,INSTRUMENTATION,NO. CONDUCTORS:3/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:ANNEALED,TIN-COATED COPPER,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,TYPE:NEC TYPE TC,(MN,SC:SR MFG: ROCKBESTOS CO, ROCKBESTOS CO, , United States Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02 The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT X17 - SUPPLEMENT DOCUMENTS					
40	120230	I46-3433	FT	3000	30-Oct-26	SR
	CABLE,INSTRUMENTATION,NO. CONDUCTORS:4/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER TINNED,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:TC,(SPEC. RSS-3-,SC:SR MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States					

	<p>Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02</p> <p>The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X17 - SUPPLEMENT DOCUMENTS</p>					
41	120230	I46-3433	FT	4000	30-Oct-27	SR
	<p>CABLE,INSTRUMENTATION,NO. CONDUCTORS:4/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER TINNED,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:TC,(SPEC. RSS-3-,SC:SR</p> <p>MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States</p> <p>Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02</p> <p>The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X17 - SUPPLEMENT DOCUMENTS</p>					
42	150070	I46-3444	FT	3000	30-Oct-26	SR
	<p>CABLE,INSTRUMENTATION,NO. CONDUCTORS:5/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,TYPE:NEC TYPE TC,(ROCKBESTOS PRODUCT CODE I46-3444),SC:SR</p> <p>MFG: ROCKBESTOS CO, ROCKBESTOS CO, , United States</p>					
43	150070	I46-3444	FT	2000	30-Oct-27	SR
	<p>CABLE,INSTRUMENTATION,NO. CONDUCTORS:5/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,TYPE:NEC TYPE TC,(ROCKBESTOS PRODUCT CODE I46-3444),SC:SR</p> <p>MFG: ROCKBESTOS CO, ROCKBESTOS CO, , United States</p>					
44	118729	I46-3425	FT	3000	30-Oct-26	SR
	<p>CABLE,INSTRUMENTATION,NO. CONDUCTORS:7/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:NEC TYPE TC,(MNF.:ROCKBESTOS),SC:SR</p>					

	MFG: ROCKBESTOS CO, ROCKBESTOS CO, , United States Item shall be supplied in accordance with the following TQRs: F03, F66, F80, F81, F82, F84, F85, F86, F88 The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS					
45	118729	I46-3425	FT	2000	31-Mar-28	SR
	CABLE,INSTRUMENTATION,NO. CONDUCTORS:7/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:NEC TYPE TC,(MNF.:ROCKBESTOS),SC:SR MFG: ROCKBESTOS CO, ROCKBESTOS CO, , United States Item shall be supplied in accordance with the following TQRs: F03, F66, F80, F81, F82, F84, F85, F86, F88 The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS					
46	118769	I46-3447	FT	3000	30-Oct-26	SR
	CABLE,INSTRUMENTATION,NO. CONDUCTORS:9/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,TYPE:TC,(NEC TYPE TC, ROCKBESTOS PRODUCT CODE I46-3447),SC:SR MFG: ROCKBESTOS CO, ROCKBESTOS CO, , United States Item shall be supplied in accordance with the following TQRs: A031, F03, F66, F80, F81, F82, F84, F85, F86, F88, G021 The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS					
47	118769	I46-3447	FT	2000	30-Oct-27	SR
	CABLE,INSTRUMENTATION,NO. CONDUCTORS:9/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,TYPE:TC,(NEC TYPE TC, ROCKBESTOS PRODUCT CODE I46-3447),SC:SR MFG: ROCKBESTOS CO, ROCKBESTOS CO, , United States Item shall be supplied in accordance with the following TQRs: A031, F03, F66, F80, F81, F82, F84, F85, F86, F88, G021 The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS					
48	124710	I46-3449	FT	3000	30-Oct-26	SR

	<p>CABLE,INSTRUMENTATION,NO. CONDUCTORS:12/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER TINNED,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,SC:SR</p> <p>MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States</p> <p>Item shall be supplied in accordance with the following TQRs: A03, F03, F80, F81, F82, F84, F85, F86, F88</p> <p>The following documents and/or records shall be submitted with the above item: G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS</p>					
49	124710	I46-3449	FT	2000	31-Mar-28	SR
	<p>CABLE,INSTRUMENTATION,NO. CONDUCTORS:12/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER TINNED,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,SC:SR</p> <p>MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States</p> <p>Item shall be supplied in accordance with the following TQRs: A03, F03, F80, F81, F82, F84, F85, F86, F88</p> <p>The following documents and/or records shall be submitted with the above item: G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS</p>					
50	118730	I46-3450	FT	3000	30-Oct-26	SR
	<p>CABLE,INSTRUMENTATION,NO. CONDUCTORS:15/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:ANNEALED,TIN-COATED COPPER,VOLTS:600V,TEMP. RATING:90DEGC,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE,SC:SR</p> <p>MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States</p> <p>Item shall be supplied in accordance with the following TQRs: F03, F80, F81, F82, F84, F85, F86, F88</p> <p>The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS</p>					
51	118730	I46-3450	FT	2000	30-Oct-27	SR
	<p>CABLE,INSTRUMENTATION,NO. CONDUCTORS:15/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:ANNEALED,TIN-COATED COPPER,VOLTS:600V,TEMP. RATING:90DEGC,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE,SC:SR</p> <p>MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States</p> <p>Item shall be supplied in accordance with the following TQRs: F03, F80, F81, F82, F84, F85, F86, F88</p> <p>The following documents and/or records shall be submitted with the above item:</p>					

	G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS					
52	118730	I46-3450	FT	2000	31-Mar-28	SR
CABLE,INSTRUMENTATION,NO. CONDUCTORS:15/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:ANNEALED,TIN-COATED COPPER,VOLTS:600V,TEMP. RATING:90DEGC,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE,SC:SR MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States Item shall be supplied in accordance with the following TQRs: F03, F80, F81, F82, F84, F85, F86, F88 The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS						
53	118731	I46-3451	FT	3000	30-Oct-26	SR
CABLE,INSTRUMENTATION,NO. CONDUCTORS:19/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:ANNEALED,TIN-COATED COPPER,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:NE,SC:SR MFG: ROCKBESTOS CO, ROCKBESTOS CO, , United States Item shall be supplied in accordance with the following TQRs: F80, F84, F88 The following documents and/or records shall be submitted with the above item: X17 - SUPPLEMENT DOCUMENTS						
54	118731	I46-3451	FT	2000	30-Oct-27	SR
CABLE,INSTRUMENTATION,NO. CONDUCTORS:19/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:ANNEALED,TIN-COATED COPPER,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:NE,SC:SR MFG: ROCKBESTOS CO, ROCKBESTOS CO, , United States Item shall be supplied in accordance with the following TQRs: F80, F84, F88 The following documents and/or records shall be submitted with the above item: X17 - SUPPLEMENT DOCUMENTS						
55	118731	I46-3451	FT	2000	31-Mar-28	SR
CABLE,INSTRUMENTATION,NO. CONDUCTORS:19/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:ANNEALED,TIN-COATED COPPER,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:NE,SC:SR MFG: ROCKBESTOS CO, ROCKBESTOS CO, , United States Item shall be supplied in accordance with the following TQRs: F80, F84, F88						

	The following documents and/or records shall be submitted with the above item: X17 - SUPPLEMENT DOCUMENTS					
56	413584	I46-5979	FT	3000	30-Oct-26	SR
CABLE.INSTRUMENTATION,SC:SR,NO. CONDUCTORS:27/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:TIN-COATED COPPER,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,TYPE:TC MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States Item shall be supplied in accordance with the following TQRs: F03, F80, F81, F82, F84, F85, F86, F88 The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS						
57	413584	I46-5979	FT	2000	30-Oct-27	SR
CABLE.INSTRUMENTATION,SC:SR,NO. CONDUCTORS:27/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:TIN-COATED COPPER,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,TYPE:TC MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States Item shall be supplied in accordance with the following TQRs: F03, F80, F81, F82, F84, F85, F86, F88 The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS						
58	413584	I46-5979	FT	2000	31-Mar-28	SR
CABLE.INSTRUMENTATION,SC:SR,NO. CONDUCTORS:27/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:TIN-COATED COPPER,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,TYPE:TC MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States Item shall be supplied in accordance with the following TQRs: F03, F80, F81, F82, F84, F85, F86, F88 The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS						
59	419235	I46-5980	FT	3000	30-Oct-26	SR
CABLE,INSTRUMENTATION,NO. CONDUCTORS:37/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:ANNEALED,TIN-COATED COPPER,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,SC:SR MFG: ROCKBESTOS CO, ROCKBESTOS CO, , United States Item shall be supplied in accordance with the following TQRs:						

	A03, F80, F85, F86, F88					
60	419235	I46-5980	FT	2000	30-Oct-27	SR
CABLE,INSTRUMENTATION,NO. CONDUCTORS:37/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:ANNEALED,TIN-COATED COPPER,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,SC:SR						
MFG: ROCKBESTOS CO, ROCKBESTOS CO, , United States						
Item shall be supplied in accordance with the following TQRs: A03, F80, F85, F86, F88						
61	419235	I46-5980	FT	2000	31-Mar-28	SR
CABLE,INSTRUMENTATION,NO. CONDUCTORS:37/C,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:ANNEALED,TIN-COATED COPPER,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,SC:SR						
MFG: ROCKBESTOS CO, ROCKBESTOS CO, , United States						
Item shall be supplied in accordance with the following TQRs: A03, F80, F85, F86, F88						
62	120232	I46-5844	FT	2500	30-Oct-26	SR
CABLE,INSTRUMENTATION,NO. CONDUCTORS:4/P,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-SHIELDED PAIRS,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,TYPE:TC,SC:SR						
MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States						
Item shall be supplied in accordance with the following TQRs: F03, F80, F81, F82, F84, F85, F86, F88						
The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS						
63	120232	I46-5844	FT	2500	30-Oct-27	SR
CABLE,INSTRUMENTATION,NO. CONDUCTORS:4/P,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-SHIELDED PAIRS,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,TYPE:TC,SC:SR						
MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States						
Item shall be supplied in accordance with the following TQRs: F03, F80, F81, F82, F84, F85, F86, F88						
The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS						
64	123223	I46-5702	FT	3000	30-Oct-26	SR

	<p>CABLE,INSTRUMENTATION,NO. CONDUCTORS:7PAIRS,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER TINNED,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-SHIELDED PAIRS,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,SC:SR</p> <p>MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States</p> <p>Item shall be supplied in accordance with the following TQRs: F03, F66, F80, F81, F82, F84, F85, F86, F88</p> <p>The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS</p>					
65	123223	I46-5702	FT	2000	30-Oct-27	SR
	<p>CABLE,INSTRUMENTATION,NO. CONDUCTORS:7PAIRS,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER TINNED,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-SHIELDED PAIRS,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,SC:SR</p> <p>MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States</p> <p>Item shall be supplied in accordance with the following TQRs: F03, F66, F80, F81, F82, F84, F85, F86, F88</p> <p>The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS</p>					
66	120231	I46-5988	FT	3000	30-Oct-26	SR
	<p>CABLE,INSTRUMENTATION,NO. CONDUCTORS:9/P,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-SHIELDED PAIRS,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,TYPE:TC,SC:SR</p> <p>MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States</p> <p>Item shall be supplied in accordance with the following TQRs: F03, F80, F81, F82, F84, F85, F86, F88</p> <p>The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS</p>					
67	120231	I46-5988	FT	2000	30-Oct-27	SR
	<p>CABLE,INSTRUMENTATION,NO. CONDUCTORS:9/P,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-SHIELDED PAIRS,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,TYPE:TC,SC:SR</p> <p>MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States</p> <p>Item shall be supplied in accordance with the following TQRs: F03, F80, F81, F82, F84, F85, F86, F88</p> <p>The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS</p>					

68	143565	I46-5703	FT	3000	30-Oct-26	SR
	CABLE,INSTRUMENTATION,NO. CONDUCTORS:12/P,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER TINNED,VOLTS:600V,TEMP. RATING:90DEGC,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,(SPEC. RSS-3-021, MNF.:ROCKBESTOS COMP.),SC:SR					
	MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States					
	<p>Item shall be supplied in accordance with the following TQRs: A03, F03, F80, F81, F82, F84, F85, F86, F88</p> <p>The following documents and/or records shall be submitted with the above item: G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS</p>					
69	143565	I46-5703	FT	2000	30-Oct-27	SR
	CABLE,INSTRUMENTATION,NO. CONDUCTORS:12/P,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER TINNED,VOLTS:600V,TEMP. RATING:90DEGC,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,(SPEC. RSS-3-021, MNF.:ROCKBESTOS COMP.),SC:SR					
	MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States					
	<p>Item shall be supplied in accordance with the following TQRs: A03, F03, F80, F81, F82, F84, F85, F86, F88</p> <p>The following documents and/or records shall be submitted with the above item: G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS</p>					
70	118772	I46-5990	FT	2000	30-Oct-26	SR
	CABLE,INSTRUMENTATION,NO. CONDUCTORS:19/P,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-SHIELDED PAIRS,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,TYPE:TC,(19PAIRS,MULTI-SHIELDED PAIRS WITH OVERALL SHIELD,NEC TYPE,SC:SR					
	MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States					
71	118772	I46-5990	FT	3000	30-Oct-27	SR
	CABLE,INSTRUMENTATION,NO. CONDUCTORS:19/P,CONDUCTOR SIZE:16AWG,SOLID/STRANDED:7 STRAND,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-SHIELDED PAIRS,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,TYPE:TC,(19PAIRS,MULTI-SHIELDED PAIRS WITH OVERALL SHIELD,NEC TYPE,SC:SR					
	MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States					
72	124709	I57-0371	FT	3000	30-Oct-26	SR
	CABLE,INSTRUMENTATION,NO. CONDUCTORS:37/C,CONDUCTOR SIZE:18AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER TINNED,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-CONDUCTOR SHIELDED,INSUL.					

	MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,SC:SR MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States Item shall be supplied in accordance with the following TQRs: F03, F80, F81, F82, F84, F85, F86, F88 The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS					
73	124709	I57-0371	FT	2000	30-Oct-27	SR
	CABLE,INSTRUMENTATION,NO. CONDUCTORS:37/C,CONDUCTOR SIZE:18AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER TINNED,VOLTS:600V,TEMP. RATING:90C,SHIELDING:MULTI-CONDUCTOR SHIELED,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,SC:SR MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States Item shall be supplied in accordance with the following TQRs: F03, F80, F81, F82, F84, F85, F86, F88 The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS					
74	433938	I57-0034	FT	2000	30-Oct-26	SR
	CABLE,INSTRUMENTATION,NO. CONDUCTORS:3 PAIR,CONDUCTOR SIZE:18AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER TINNED,VOLTS:600V,TEMP. RATING:90DEGC,SHIELDING:MULTI-SHIELED PAIRS WITH OVERALL SHIELD ,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:TC,SC:SR MFG: ROCKBESTOS CO, ROCKBESTOS CO, , United States					
75	433938	I57-0034	FT	1000	30-Oct-27	SR
	CABLE,INSTRUMENTATION,NO. CONDUCTORS:3 PAIR,CONDUCTOR SIZE:18AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER TINNED,VOLTS:600V,TEMP. RATING:90DEGC,SHIELDING:MULTI-SHIELED PAIRS WITH OVERALL SHIELD ,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:TC,SC:SR MFG: ROCKBESTOS CO, ROCKBESTOS CO, , United States					
76	149748	I57-0044	FT	2000	30-Oct-26	SR
	CABLE,INSTRUMENTATION,NO. CONDUCTORS:4 PAIR,CONDUCTOR SIZE:18AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER TINNED,VOLTS:600V,TEMP. RATING:90DEGC,SHIELDING:MULTI-SHIELED PAIRS,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:TC,SC:SR MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States Item shall be supplied in accordance with the following TQRs: F03, F80, F81, F82, F84, F85, F86, F88 The following documents and/or records shall be submitted with the above item:					

	G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS					
77	149748	I57-0044	FT	1000	30-Oct-27	SR
CABLE,INSTRUMENTATION,NO. CONDUCTORS:4 PAIR,CONDUCTOR SIZE:18AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER TINNED,VOLTS:600V,TEMP. RATING:90DEGC,SHIELDING:MULTI-SHIELDED PAIRS,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:TC,SC:SR MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States Item shall be supplied in accordance with the following TQRs: F03, F80, F81, F82, F84, F85, F86, F88 The following documents and/or records shall be submitted with the above item: G44 - DIELECTRIC STRENGTH TEST RECORD G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383 X17 - SUPPLEMENT DOCUMENTS						
78	421121	I57-0124	FT	1000	30-Oct-27	SR
CABLE,INSTRUMENTATION,NO. CONDUCTORS:12 PAIR,CONDUCTOR SIZE:18AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER TINNED,VOLTS:600V,TEMP. RATING:90DEGC,SHIELDING:MULTI-SHIELDED PAIRS,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:TC,SC:SR MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02 The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT X17 - SUPPLEMENT DOCUMENTS						
79	421120	I57-0194	FT	1000	30-Oct-27	SR
CABLE,INSTRUMENTATION,NO. CONDUCTORS:19 PAIR,CONDUCTOR SIZE:18AWG,SOLID/STRANDED:7 STRAND,CONDU. MATERIAL:COPPER TINNED,VOLTS:600V,TEMP. RATING:90DEGC,SHIELDING:MULTI-SHIELDED PAIRS,INSUL. MATERIAL:XLPE/CSPE,CLASS:1E NUCLEAR,COLOR:BLACK,TYPE:TC,SC:SR MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States Item shall be supplied in accordance with the following TQRs: A00, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02 The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN						

	GP4 - PRODUCT DATA SHEET X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT X17 - SUPPLEMENT DOCUMENTS					
80	120307	A82-0146	FT	5000	30-Oct-26	SR
WIRE, SWITCHBOARD, CONDUCTOR SIZE: 14AWG, SOLID/STRANDED: 7 STRAND, CONDU. MATERIAL: COPPER, VOLTS: 600V, TEMP. RATING: 90C, INSUL. MATERIAL: XLPE, CLASS: 1E NUCLEAR, COLOR: GRAY, TYPE: SIS, (SPEC. RSS-4-002, MNF.: ROCKBESTOS), SC: SR MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States Item shall be supplied in accordance with the following TQRs: A00, A03, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02 The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X083 - CERTIFICATE OF COMPLIANCE TO QUALIFICATION REPORT QR-5804 or QR-5805 X17 - SUPPLEMENT DOCUMENTS						
81	120307	A82-0146	FT	7500	30-Oct-27	SR
WIRE, SWITCHBOARD, CONDUCTOR SIZE: 14AWG, SOLID/STRANDED: 7 STRAND, CONDU. MATERIAL: COPPER, VOLTS: 600V, TEMP. RATING: 90C, INSUL. MATERIAL: XLPE, CLASS: 1E NUCLEAR, COLOR: GRAY, TYPE: SIS, (SPEC. RSS-4-002, MNF.: ROCKBESTOS), SC: SR MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States Item shall be supplied in accordance with the following TQRs: A00, A03, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02 The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X083 - CERTIFICATE OF COMPLIANCE TO QUALIFICATION REPORT QR-5804 or QR-5805 X17 - SUPPLEMENT DOCUMENTS						
82	120307	A82-0146	FT	2500	31-Mar-28	SR
WIRE, SWITCHBOARD, CONDUCTOR SIZE: 14AWG, SOLID/STRANDED: 7 STRAND, CONDU. MATERIAL: COPPER, VOLTS: 600V, TEMP. RATING: 90C, INSUL. MATERIAL: XLPE, CLASS: 1E NUCLEAR, COLOR: GRAY, TYPE: SIS, (SPEC. RSS-4-002, MNF.: ROCKBESTOS), SC: SR MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States Item shall be supplied in accordance with the following TQRs: A00, A03, A07, B00, B01, B04, B06, B07, B08, C00, C01, F00, F03, F80, F81, F82, F84, F85, F86, F88, F90, G00, G01, G02 The following documents and/or records shall be submitted with the above item: G04 - THE CERTIFICATE OF CONFORMANCE G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS						

	G22 - NONCONFORMANCE REPORTS G44 - DIELECTRIC STRENGTH TEST RECORD GC1 - CERTIFICATE OF ORIGIN GP4 - PRODUCT DATA SHEET X083 - CERTIFICATE OF COMPLIANCE TO QUALIFICATION REPORT QR-5804 or QR-5805 X17 - SUPPLEMENT DOCUMENTS					
83	131270	A82-0166	FT	10000	30-Oct-26	SR
	WIRE, SWITCHBOARD, CONDUCTOR SIZE: 16AWG, SOLID/STRANDED: 7 STRAND, CONDU. MATERIAL: COPPER TIN-COATED, VOLTS: 600V, TEMP. RATING: 90DEGC, INSUL. MATERIAL: XLPE, CLASS: 1E NUCLEAR, COLOR: GRAY, TYPE: SIS, SC: SR					
	MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States					
84	131270	A82-0166	FT	5000	30-Oct-27	SR
	WIRE, SWITCHBOARD, CONDUCTOR SIZE: 16AWG, SOLID/STRANDED: 7 STRAND, CONDU. MATERIAL: COPPER TIN-COATED, VOLTS: 600V, TEMP. RATING: 90DEGC, INSUL. MATERIAL: XLPE, CLASS: 1E NUCLEAR, COLOR: GRAY, TYPE: SIS, SC: SR					
	MFG: ROCKBESTOS CO., 20 BRADLEY PARK ROAD, 06026-1102 EAST GRANDBY, United States					

2. TECHNICAL AND QUALITY REQUIREMENTS

IMPORTANT:

The quotation has to include Statement of Compliance with the Technical and Quality Requirements from Purchaser's RFQ including the Bidder's commitment to provide requested documents and/or records. If any of these requirements cannot be fulfilled, please, provide the explanation.

A00 - GENERAL REQUIREMENTS

ALL REQUIRED DOCUMENTS SHALL BE SUPPLIED IN ENGLISH OR ENGLISH/ MULTILINGUAL.

A03 - ORDER ENTRY/DROP SHIP REQUIREMENTS

THE SALES OFFICE RECEIVING THIS PURCHASE ORDER SHALL TRANSMIT ALL NEK PURCHASE ORDER REQUIREMENTS TO THE EQUIPMENT/ ITEM MANUFACTURER. ALL ITEMS SHALL BE DROP SHIPPED DIRECTLY FROM THE MANUFACTURER TO THE NEK FACILITY SPECIFIED ON THE PURCHASE ORDER.

A031 - ORDER ENTRY/DROP SHIP REQUIREMENTS

THE SALES OFFICE RECEIVING THIS PURCHASE ORDER SHALL TRANSMIT ALL NEK PURCHASE ORDER REQUIREMENTS TO THE EQUIPMENT MANUFACTURER. ALL ITEMS SHALL BE DROP SHIPPED DIRECTLY FROM THE SUPPLIER TO THE NEK FACILITY SPECIFIED ON THE PURCHASE ORDER.

A07 - NEW ITEMS

ALL ITEM(S) PROVIDED ON THIS PURCHASE ORDER SHALL BE SUPPLIED IN THE NEW CONDITION (NOT USED OR REFURBISHED IN ANY WAY).

B00 - QUALITY ASSURANCE REQUIREMENTS

B01 - QUALITY ASSURANCE PROGRAM

ALL SERVICES AND ITEMS, INCLUDING THOSE WHICH HAVE TO COMPLY WITH ASME CODE REQUIREMENTS, SHALL BE SUPPLIED IN ACCORDANCE WITH A QUALITY ASSURANCE PROGRAM THAT COMPLIES WITH 10CFR50 APPENDIX B AND ANSI N45.2-1977 OR ASME NQA-1, AND THAT HAS BEEN PREVIOUSLY EVALUATED AND ACCEPTED BY NEK.

B04 - SUPPLIER QA MANUAL CONTROLLED DISTRIBUTION

IF A CONTROLLED COPY OF THE LATEST REVISION OF THE SUPPLIER'S QUALITY ASSURANCE PROGRAM MANUAL HAS NOT BEEN PREVIOUSLY SENT TO NEK, SUBMIT A COPY OF THIS DOCUMENT TO:

LUKA MIKELIĆ, QUALITY & NUCLEAR OVERSIGHT DIRECTOR
tel.:++386 748 02 429
E-mail:luka.mikelic@nek.si

IF A REVISION TO THE SUPPLIER'S QUALITY ASSURANCE MANUAL IS MADE DURING THE CONDUCT OF WORK ASSOCIATED WITH THIS ORDER, A COPY OF THE REVISION SHALL BE SUBMITTED TO THE ABOVE ADDRESS PRIOR TO IMPLEMENTATION OF THE CHANGE.

B06 - 10CFR21 REPORTING

THIS ORDER IS SUBJECT THE PROVISIONS OF THE TITLE 10 OF THE U.S. CODE OF FEDERAL REGULATIONS PART 21, REPORTING OF DEFECTS AND NONCOMPLIANCE, REPORTING PURSUANT TO 10CFR21 SHALL BE MADE TO:

STANKO MANOJLOVIC , ENGINEERING SUPPORT FOR LONG TERM OPERATION SUPERINTENDENT
tel.:++386 748 02 527
E-MAIL: stanko.manojlovic@nek.si

B07 - RIGHTS OF ACCESS

NUCLEAR POWER PLANT KRSKO (NEK)) SHALL HAVE THE RIGHT OF ACCESS TO THE SUPPLIER'S AND ANY SUBTIER SUPPLIER'S FACILITIES AND RECORDS FOR INSPECTION OR AUDIT BY NEK , THEIR DESIGNATED REPRESENTATIVE AND/OR OTHER PARTIES AUTHORIZED BY NEK. THIS SHALL INCLUDE, BUT IS NOT LIMITED TO, THE RIGHT TO AUDIT MATERIAL, TEST, INSPECTION SERVICES AND QUALITY RECORDS; MAKE SURVEILLANCE VISITS DURING MANUFACTURING; AND WITNESS TESTS TO THE EXTENT NEK DEEMS NECESSARY TO ASSURE THAT WORK IS BEING PERFORMED IN ACCORDANCE WITH ALL PRODUCT DESIGN AND MANUFACTURING REQUIREMENTS. NEK WILL MAKE ARRANGMENT FOR ANY SUBTIER AUDIT OR INSPECTION THROUGH SUPPLIER. SUPPLIER WILL HAVE OPTION TO ACCOMPANY NEK DURING ANY SUB-SUPPLIER AUDITS OR INSPECTIONS.

INSPECTIONS OR EXAMINATIONS PERFORMED BY NEK, OR ITS DESIGNATED REPRESENTATIVES, DO NOT RELIEVE THE SUPPLIER OF ITS RESPONSIBILITY TO MEET THE REQUIREMENTS OF THIS PURCHASE ORDER.

B08 - RETENTION OF RECORDS

A RECORD SYSTEM (RETENTION TIME FOR LIFETIME AND NON-PERMANENT RECORDS) SHALL BE ESTABLISHED AND MAINTAINED BY THE SUPPLIER THAT PROVIDES DOCUMENTARY EVIDENCE OF THE QUALITY OF THE ITEMS AND ACTIVITIES AFFECTING QUALITY. THESE QA RECORDS SHALL INCLUDE RESULTS OF REVIEWS, INSPECTIONS, TESTS, AUDITS, MONITORING OF WORK PERFORMANCE AND MATERIAL ANALYSIS. RECORDS SHALL, AS A MINIMUM, IDENTIFY THE INSPECTOR OR DATA RECORDER, DATE INSPECTION WAS PERFORMED, TYPE OF OBSERVATION, PROCEDURES USED, RESULTS, ACCEPTABILITY, AND ACTION TAKEN FOR DEFICIENCIES NOTED. ADDITIONAL RECORDS OF SUPPORTING DATA SHALL ALSO BE MAINTAINED. ALL QUALITY VERIFICATION RECORDS, PROCEDURES AND QUALIFICATIONS SHALL BE IDENTIFIABLE TO THE ITEM OR ACTIVITY INVOLVED. THESE RECORDS SHALL BE RETRIVEABLE AND AVAILABLE FOR EXAMINATION. THE CLASSIFICATION AND RETENTION TIME OF LIFETIME AND NON-PERMANENT RECORDS SHALL BE IN COMPLIANCE WITH THE REQUIREMENTS OF USNRC REGULATORY GUIDE 1.28, REV. 3-1985. THE SUPPLIER MAY DISPOSE OF NON-PERMANENT RECORDS AFTER THE REQUIRED RETENTION PERIOD. IF THE SUPPLIER GOES OUT OF BUSINESS BEFORE THE END OF THE RETENTION PERIOD OF THESE RECORDS, THE SUPPLIER WILL SEND ONE COPY OF THESE RECORDS TO THE NEK IMPORT DEPARTMENT SUPERINTENDENT.

C00 - NONCONFORMANCE AND DEVIATION**C01 - NO SUBSTITUTIONS**

THE SUPPLIER SHALL NOT SUBSTITUTE OTHER ITEMS FOR THE ITEMS REQUESTED WITHOUT SPECIFIC WRITTEN APPROVAL OF NEK PRIOR TO SHIPMENT. IF THE SUPPLIER IDENTIFIES CHANGES, NONCONFORMANCES, OR SEEKS WAIVERS FROM OTHER REQUIREMENTS OF THIS PURCHASE ORDER, THE SUPPLIER SHALL DESCRIBE SUCH CONDITIONS AND THIS INFORMATION SHALL BE TRANSMITTED, IN WRITING, TO NEK IMPORT DEPARTMENT SUPERINTENDENT.

IF THE REQUESTED INFORMATION IS APPROVED BY NEK, THE SUPPLIER SHALL INCLUDE AN APPROVED COPY OF THE INFORMATION STATEMENT WITH THE ITEMS SHIPPED.

THE SUPPLIER SHALL IDENTIFY ANY CHANGE MADE TO UPGRADE ANY ITEM ON THIS PURCHASE ORDER AS A RESULT OF USNRC CORRESPONDENCE (SUCH AS INFORMATION NOTICES, BULLETINS AND ADVISORY LETTERS). CHANGES AS PART OF THE SUPPLIER'S PRODUCT IMPROVEMENT PROGRAM SHALL ALSO BE IDENTIFIED AND TRANSMITTED IN WRITING TO THE NEK IMPORT DEPARTMENT SUPERINTENDENT FOR APPROVAL.

F00 - SHIPPING, HANDLING, MARKING AND STORAGE INSTRUCTIONS ;

F03 - HANDLING, PACKAGING AND SHIPPING

HANLING, PACKAGING AND SHIPING OF THE ITEM SUPPLIED UNDER THIS PURCHASE ORDER SHALL BE IN ACCORDANCE WITH AMERICAN NATIONAL STANDARDS INSTITUTE (ANSI) N45.2.2-LEVEL C.

F66 - UL LABEL/STAMP**F80 - CABLE REEL MARKINGS AND CABLE LENGTH REQUIREMENTS****F81 - CONTRACT OR P.O.****F82 - NEK ITEM NUMBER****F84 - RELL NO.****F85 - CABLE LENGTH**

MINIMAL CABLE LENGTH ON A REEL MUST BE AT LEAST 2000FT OR AS ORDERED PER SHIPMENT.

F86 - CONDUCTOR SIZE**F88 - PART NUMBER****F90 - PACKING SLIPS ARE TO BE SHIPPED WITH ORDER****G00 - SUPPLIER DOCUMENTATION REQUIREMENTS**

ALL REQUIRED DOCUMENTS SHALL BE SUPPLIED IN ORIGINAL HARD COPY OR ELECTRONIC FORM DEFINED BY SUPPLIER QA PROGRAM AND ACCEPTED BY NEK.

G01 - DOCUMENT TRACEABILITY

ALL REQUIRED DOCUMENTS SHALL BE TRACEABLE TO THE NEK PURCHASE ORDER. DOCUMENTS SUPPLIED WHICH ARE ASSOCIATED WITH SPECIFIC ITEMS ON THE ORDER, SUCH AS TEST REPORTS, SHALL BE IDENTIFIED IN ORDER TO ESTABLISH TRACEABILITY TO THAT ITEM OR GROUP OF ITEMS.

G02 - MATERIAL AND DOCUMENTATION SHIPPING

MATERIAL AND ALL CERTIFICATIONS OR ACCOMPANYING DOCUMENTATION SUPPLIED UNDER THIS ORDER SHALL BE DIRECTLY SHIPPED FROM THE SUPPLIER/MANUFACTURER TO NEK. THE DISTRIBUTOR SHALL NOT TAKE POSSESSION OF MATERIAL OR DOCUMENTATION.

G021 - MATERIAL AND DOCUMENTATION SHIPPING

MATERIAL AND ALL CERTIFICATIONS OR ACCOMPANYING DOCUMENTATION SUPPLIED UNDER THIS ORDER SHALL BE DIRECTLY SHIPPED FROM THE SUPPLIER TO NEK. THE SUPPLIER SHALL SEND TO NEK EITHER ALL ORIGINAL MATERIAL DOCUMENTATION PROVIDING QUALITY OF THE PRODUCT OR COPIES OF ORIGINAL DOCUMENTATION SIGNED BY NOTARY PUBLIC.

G04 - THE CERTIFICATE OF CONFORMANCE

THE CERTIFICATE OF CONFORMANCE SHALL SATISFY THE FOLLOWING CRITERIA:

1. IDENTIFY THE PURCHASE ORDER NUMBER, INCLUDING ITEM NUMBERS AND CHANGE ORDER NUMBER APPLICABLE TO THE ITEM BEING CERTIFIED.
2. A PERSON IDENTIFIED IN THE SUPPLIER'S QUALITY ASSURANCE PROGRAM DESCRIPTION AS RESPONSIBLE FOR CERTIFICATION SHALL ATTEST TO THE CERTIFICATE BY SIGNATURE, TITLE AND DATE OF SIGNING.
3. NEK RESERVES THE RIGHT TO DETERMINE THE VALIDITY OF THE CERTIFICATE OF CONFORMANCE BY AN AUDIT OF THE SUPPLIER OR BY AN INSPECTION OR TEST OF THE ITEM(S).

G07 - CERTIFICATION TO SUPPLIER CATALOG SPECIFICATIONS

MATERIAL SUPPLIED BY THE SUPPLIER SHALL BE ACCOMPANIED BY A CERTIFICATION CONTAINING THE SIGNATURE OF A REPRESENTATIVE OF THE SUPPLIER RESPONSIBLE FOR THE QUALITY FUNCTION STATING THAT ALL ITEMS SUPPLIED MEET THE SPECIFICATIONS AND THE REQUIREMENTS AS STATED IN THE SUPPLIERS CATALOG. THE NEK PURCHASE ORDER NUMBER SHALL BE STATED ON THE CERTIFICATION.

G22 - NONCONFORMANCE REPORTS

THE SUPPLIER SHALL PROVIDE A COPY OF ALL NONCONFORMANCE REPORTS AS REPAIR OR USE-AS-IS DISPOSITION OF MATERIALS DURING THE MANUFACTURING PROCESS TO UTILITIES ONLY IN CASES THAT AFFECT ENVIRONMENTAL QUALIFICATION, INTERCHANGEABILITY, DESIGN OR OPERATING PARAMETERS GENERATED DURING MANUFACTURE OF PROCESSING OF THIS ORDER.

THIS REPORT SHALL INCLUDE TECHNICAL JUSTIFICATION FOR NONCONFORMANCE DISPOSITIONS. ALL DISPOSITIONS WHICH DO NOT RETURN AN ITEM TO THE CONDITIONS STATED IN AN APPROVED DRAWING OR SPECIFICATION SHALL BE APPROVED BY NEK PRIOR TO THE SHIPMENT OF THE AFFECTED ITEM.

G44 - DIELECTRIC STRENGTH TEST RECORD**G86 - CERTIFICATE OF COMPLIANCE TO IEEE 323/383**

ROCKBESTOS SHALL PROVIDE A CERTIFICATION SHOWING THE ITEM(S) HAS BEEN QUALIFIED IN ACCORDANCE WITH: IEEE 323, IEEE 383, SPECIFICATION RSS-3-021 AND QUALIFICATION REPORTS: CHEMICALLY CROSS-LINKED QR-5804 REV.3 OR IRRADIATION CURE (QR-0801 REV.1 OR QR-5805 REV.2).

GC1 - CERTIFICATE OF ORIGIN**GP4 - PRODUCT DATA SHEET****X082 - CERTIFICATE OF COMPLIANCE TO TEST REPORT**

THE SUPPLIER SHALL PROVIDE A CERTIFICATION SHOWING THE ITEM(S) HAS BEEN QUALIFIED IN ACCORDANCE WITH: IEEE 323, IEEE 383, SPECIFICATION RSS-3-021 AND QUALIFICATION REPORTS: QR-2301, Rev.0.

X083 - CERTIFICATE OF COMPLIANCE TO QUALIFICATION REPORT QR-5804 or QR-5805

ROCKBESTOS SHALL PROVIDE A CERTIFICATION SHOWING THE ITEM(S) HAS BEEN QUALIFIED IN ACCORDANCE WITH: IEEE 323, IEEE 383, SPECIFICATION RSS-4-002 AND QUALIFICATION REPORTS: QR-5804 or QR-5805.

For item: 118769,118769

X17 - SUPPLEMENT DOCUMENTS

THE SUPPLEMENT DOCUMENTS SHALL INCLUDE: CERTIFIED TEST REPORT

For item:

118727,118727,118729,118729,118730,118730,118730,118731,118731,118731,118770,120217,120217,120230,120230,120231,120231,120232,120232,120304,120307,120307,120307,120963,120965,120965,120967,123084,123084,123084,123223,123223,123700,123701,123702,123703,123703,123704,123704,124709,124709,124710,124710,124712,143565,143565,144490,144490,149748,149748,149752,154810,154810,154810,154811,154811,154811,154811,235373,407426,413584,413584,413584,420109,420110,420111,420112,420132,421120,421121,432739

X17 - SUPPLEMENT DOCUMENTS

THE SUPPLEMENT DOCUMENTS SHALL INCLUDE:

CERTIFIED TEST REPORT:

- SEE TQR G44,
- CONDUCTOR RESISTANCE,
- INSULATION RESISTANCE,
- DIMENSIONAL DATA (OVERALL DIAMETER, INSULATION AND JACKET).