

1	2	3	4	5	6	7	8				
KARAKTERISTIKE ENERGETSKEGA NAPAJANJA	Diagram description: The diagram shows a power supply system. It starts with 'NN drog' (NN line) at the top, leading to 'obstoječ primarni NN priključek' (existing primary NN connection). This leads into a dashed box labeled '=DVORIŠČE' (source), which contains a box labeled '+PS-PMR' and 'obstoječ priključno merilni razdelilnik' (existing connection point measurement distribution unit). Below this, a red line labeled 'obstoječe merilno mesto' (existing measurement point) leads into another dashed box labeled '=SKLADIŠČNI PROSTOR' (storage space), which contains a box labeled '+R1' and 'inštalacijski razdelilnik' (installation distribution unit). Below this, a red line labeled '-U1 pren. zaščita razred II' (II class protective conductor) leads to a ground symbol. A legend at the bottom left indicates that black lines represent 'obstoječe' (existing) and red lines represent 'predmet načrta' (subject of the plan).										
Sistem napajanja: TN-C											
Nazivna napetost, frekvenca: U=400/230V AC, f=50Hz											
Krmilna napetost: Ua=230V AC											
Inštalirana moč: Pi=45.4kW											
Faktor istočasnosti: fi=0.55											
Konična moč: Pk=24.9kW											
Faktor moči: cos fi=0,95											
Konični tok: Ik=44.4A											
LEGENDA: — obstoječe — predmet načrta											
Opis spremembe	Datum	Podpis	Ime in priimek	Ident. št.	Investitor in objekt: OBČINA ROGAŠOVCI: OBJEKT ZA STALNO RAZSTAVO O KULTURNI KRAJINI GORIČKEGA		Vrsta projekta: PZI	Številka mape: 3	Datum izdelave: Maj 2026	List: 1	
			Vodja proj.	Tadeja Madjar Stajno, u.d.i.a.	PA A-1398	Naslov risbe:		Št. projekta: PD-24/24	Št. načrta: ES-0-26/11	Št. risbe: P-3.1	Št.listov: 1
			Poobl. proj.	Matej PUHAN, dipl.inž.el.	PI E-2303	Naprava:		=			
			Sodelavec:	Janko SMOLKOVIČ, inž.el.	NI E-1462	BLOK SHEMA ENERGETSKEGA NAPAJANJA					