| ITEM NO. | NO. REQD. | B. M. ITEM | DESCRIPTION | MATERIAL | REF. NOTES |
|---|---|---|---|---|---|
| 1 | 1 | | L 80x8 L=200mm | NOTE 2 | DIN 1026-1 |
| 2 | 1 | | PLATE 270x270x15mm | NOTE 2 | DIN 10029 |
| 3 | 1 | A76 | U-BOLT FOR 2" PIPE | GALVANIZED STEEL | DIN 3570 |
| 4 | 4 | | ANCHOR BOLTS, HILTI HST3 M12x115 40/20 | GALVANIZED STEEL | HILTI |
| | | | | | |




FRONT VIEW




A–A (1:8)




ISO VIEW




TOP VIEW

NOTES:

1. ALL DIMENSIONS ARE IN MILIMETERS.
2. MATERIAL GRADE SHALL BE ASTM A36 OR THE EQUIVALENT (S275J2 OR S355J2).
3. SUPPORT SHALL BE SANDBLASTED AND COATED ACCORDING TO NEK PROCEDURE SP-A322.
4. ANCHORING ACCORDING TO HILTI INSTRUCTIONS.
5. THE CUT OF REBARS IS NOT PERMITED. APLLY SCANNING FOR POSITIONING OF THE ANCHOR BOLTS AND ADAPT HOLES' LOCATIONS AS NEEDED.
6. WELDING ACCORDING TO AWS D1.1. FILLET WELD. BUTT WELDS FULL PENETRATING.

ZKP
2024-1061

NON-SAFETY RELATED

1. Interim Dwg. No.: SIP-MN034-SUPPORT-005-IA
   Interim Sketch No.: N/A
2. Design Mod. No.: ZKP 2024-1061
3. Drawing Rev. No.: N/A
4. New Drawing No.: SIP-MN034-SUPPORT-005
5. Resp. Eng.: T. BROMŠE Date: 18.07.2025
6. Checker: R. MLAKAR Date: 18.07.2025

Position ISO 128

Scale 1:8

Mass

| | Date | By |
|---|---|---|
| Made | | |
| Check. | | |
| App. | | |

Name:

FD SYSTEM
PIPE SUPPORT
OPC BUILDING

Design Firm
SIPRO INŽENIRING CKŽ 135c SI-8270 KRŠKO

Drawing No.
SIP-MN034-SUPPORT-005

Sheet No. 1/1

Format: A4

| Rev. | Modification | Date | By |
|---|---|---|---|

File Name.: SIP-MN034-SUPPORT-005dwg.dwg