ITEM NO.	NO. REQD.	B. M. ITEM	DESCRIPTION	MATERIAL	REF. NOTES
1	1		L80x8, L=500mm	NOTE 2	DIN 1028
2	1	A76	U-BOLT FOR 1 1/2" PIPE	GALVANIZED STEEL	DIN 3570
3	2		ANCHOR BOLTS, HILTI HST3 M12x115 40/20	GALVANIZED STEEL	HILTI

NOTES:

1. ALL DIMENSIONS ARE IN MILIMETERS.
2. MATERIAL GRADE SHALL BE ASTM A36 OR THE EQUIVALENT (S275J2 OR S355J2).
3. SUPPORT SHALL BE SANDBLASTED AND COATED ACCORDING TO NEK PROCEDURE SP-A322.
4. ANCHORING ACCORDING TO HILTI INSTRUCTIONS.
5. THE CUT OF REBARS IS NOT PERMITED. APLLY SCANNING FOR POSITIONING OF THE ANCHOR BOLTS AND ADAPT HOLES' LOCATIONS AS NEEDED.
6. WELDING ACCORDING TO AWS D1.1. FILLET WELD. BUTT WELDS FULL PENETRATING.



FRONT VIEW



SIDE VIEW



ISO VIEW



TOP VIEW

ZKP
2024-1061

1. Interim Dwg. No.: SIP-MN034-SUPPORT-007-IA
   Interim Sketch No.: N/A
2. Design Mod. No.: ZKP 2024-1061
3. Drawing Rev. No.: N/A
4. New Drawing No.: SIP-MN034-SUPPORT-007
5. Resp. Eng.: T. BROMŠE Date: 18.07.2025
6. Checker: R. MLAKAR Date: 18.07.2025

NON-SAFETY RELATED

Position ISO 128			Scale 1:5	Mass
	Date	By	Name:	
Made			FD SYSTEM PIPE SUPPORT OPC BUILDING	
Check.				
App.				
Design Firm: SIPRO INŽENIRING, CKŽ 135c, SI-8270 KRŠKO			Drawing No.: SIP-MN034-SUPPORT-007	Sheet No. 1/1
				Format: A3
Rev.	Modification	Date	By	File Name.: SIP-MN034-SUPPORT-007dwg.dwg